

February 3, 2026

Unirac
Attn: Engineering Services Department
1411 Broadway Boulevard NE
Albuquerque, NM 87102-1545
TEL: (505) 242-6411

**RE: ENGINEERING CERTIFICATION LETTER FOR THE UNIRAC SOLARMOUNT (SM)
ROOF PV PANEL SUPPORT SYSTEM
STATE: CA
TECTONIC WORK ORDER #: 12557.135**

The Unirac SOLARMOUNT (SM) Photovoltaic Panel Support System is a proprietary framed photovoltaic panel support system that is installed on a roof. Tectonic Engineering Consultants P.C. (Tectonic) has reviewed the SM design methodology along with the U-Builder tool: a Unirac online design tool. The review included the following SM products, SM Light, Heavy Duty, and Standard rail with both the standard and pro hardware.

Tectonic has determined that the design is a rational approach and follows the structural requirements of the following reference documents:

Codes/Standards:

- 2024 International Building Code by International Code Council.
- 2025 California Building Code, Title 24, Part 2 (Volumes 1 & 2).
- ASCE/SEI 7-22 Minimum Design Loads for Buildings and Other Structures, by American Society of Civil Engineers with provision from SEAOC PV-2-2017.
- 2020 Aluminum Design Manual, by Aluminum Association.

This letter certifies that the structural analysis of the racking members, connections, and components directly related to Unirac's system are in compliance with the above state codes, standards and requirements. The design methodology is acceptable under components and cladding loads associated with the building roof structure when the system is installed in accordance with manufacturer specifications. If the loading criteria does not meet Unirac's specifications, the owner shall contact Unirac for a site-specific certification.

Attachments approved for the SM system to the structure include the following and is installed per Unirac's U-Builder report and installation guides:

- **Shingle Roof:** L-Foot Flashkit Pro, Standoffs, Flashloc Comp, Flash Loc Duo, and Flash Kit Pro SB
- **Metal Roof:** Standing Seam Attachments, PM-9000s, and PM Adjust Slotted
- **Tile Roof:** Solar hooks, Flashkit Tile Replacement (TR)

Project Contact Info

1279 Route 300 | Newburgh, NY 12550
845.567.6656 Tel | 845.567.8703 Fax

tectonicengineering.com
Equal Opportunity Employer

The U-Builder Tool should be used under the responsible charger of a registered professional engineer required by the authority having jurisdiction. The design tool and Unirac do not evaluate the existing roof structure, or the PV panels themselves. See the construction and installation drawings and manuals for additional information provided by Unirac.

Sincerely,

Tectonic



James Mark Privette, P.E.
CA PE #: C91463

Mark Privette

Digitally signed
by Mark Privette
Date: 2026.02.03
09:40:52 -05'00'

Project Contact Info

1279 Route 300 | Newburgh, NY 12550
845.567.6656 Tel | 845.567.8703 Fax

tectonicengineering.com
Equal Opportunity Employer