

August 06, 2024

Unirac
Attn: Engineering Services Department
1411 Broadway Boulevard NE
Albuquerque, NM 87102-1545
TEL: (505) 242-6411

**RE: ENGINEERING CERTIFICATION LETTER FOR THE UNIRAC SOLARMOUNT (SM)
ROOF PV PANEL SUPPORT SYSTEM
STATE: OREGON
TECTONIC WORK ORDER #: 12557.23**

The Unirac SOLARMOUNT (SM) Photovoltaic Panel Support System is a proprietary framed photovoltaic panel support system that is installed on a roof. Tectonic Engineering Consultants, Geologists & Land Surveyors, D.P.C. (Tectonic) has reviewed the SM design methodology along with the U-Builder tool; a Unirac online design tool. The review included the following SM products, SM Light, Heavy Duty, and Standard rail with both the standard and pro hardware.

Tectonic has determined that the design is a rational approach and follows the structural requirements of the following reference documents:

Codes/Standards:

- 2022 Oregon Structural Specialty Code with Amendments Effective Oct. 2023.
- 2021 International Building Code by International Code Council.
- ASCE/SEI 7-16 Minimum Design Loads for Buildings and Other Structures, by American Society of Civil Engineers with provisions from SEAOC PV-2-2017.
- 2020 Aluminum Design Manual, by Aluminum Association.

This letter certifies that the structural analysis of the racking members, connections, and components directly related to Unirac's system are in compliance with the above codes. The design methodology is acceptable under components and cladding loads associated with the building's roof structure when the system is installed in accordance with manufacturer specifications. If the loading criteria does not meet Unirac's specifications, owner shall contact Unirac for a site-specific certification.

Attachments approved for the SM system to the structure include the following and is installed per Unirac's U-Builder report and installation guides:

- **Shingle Roof:** L-Foot Flashkit Pro, Standoffs, Flashloc Comp, Flash Loc Duo, and Flash Kit Pro SB

Project Contact Info

1279 Route 300 | Newburgh, NY 12550
845.567.6656 Tel | 845.567.8703 Fax


tectonicengineering.com
Equal Opportunity Employer

- **Metal Roof:** Standing Seam Attachments, PM-9000s, and PM Adjust Slotted
- **Tile Roof:** Solar hooks, Flashkit Tile Replacement (TR)

The U-Builder Tool should be used under the responsible charge of a registered professional engineer required by the authority having jurisdiction. The design tool and Unirac do not evaluate the existing roof structure, or the PV panels themselves. See the construction and installation drawings and manuals for additional information provided by Unirac.

Sincerely,

Tectonic



Antonio A. Gualtieri, P.E.
Executive Vice President

08/06/2024

Project Contact Info

1279 Route 300 | Newburgh, NY 12550
845.567.6656 Tel | 845.567.8703 Fax

tectonicengineering.com
Equal Opportunity Employer