



Certificate: 80285418

Master Contract: 266909

Project: 80285418

Date Issued: 2026-01-19

bond pin.

Latest MLPE Tiger Clip Install Manual revision: PUB2026JAN12

APPLICABLE REQUIREMENTS

CSA TIL No. A-40:20 - PV Module and Panel Rack Mounting Systems and Accessories

ANSI/UL 2703:2015 - First Edition - Including revisions through June 11, 2025 - UL Standard for Safety Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels

Conditions Of Acceptability

The grounding of the system is intended to comply with the latest edition of the National Electrical Code, to include NEC 250 & 690. Local code compliance is required, in addition to national codes. All grounding/bonding connections are to be torqued in accordance with the Installation Manual and the settings used during the certification testing for the current edition of the project report.



Certificate: 80285418

Master Contract: 266909

Project: 80285418

Date Issued: 2026-01-19

Notes:

Products certified under Class(es) C531391, C531392 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

